



# Borough of Narberth

## PERMIT APPLICATION

### Curb & Sidewalk

FOR BOROUGH USE ONLY	
Application #:	<input type="text"/> <input type="text"/> <input type="text"/> <input type="text"/> <input type="text"/>
Parcel ID: 12-00-	<input type="text"/> <input type="text"/> <input type="text"/> <input type="text"/> <input type="text"/> <input type="text"/> <b>00</b> <input type="text"/>

#### PROPERTY INFORMATION

Owner Name: \_\_\_\_\_ Today's Date: \_\_\_\_\_

Address: \_\_\_\_\_, Narberth, PA 19072

Owner Address: \_\_\_\_\_

Owner Phone #: \_\_\_\_\_ Owner Email: \_\_\_\_\_

#### PROJECT INFORMATION

Contractor Name: \_\_\_\_\_

Contractor Address: \_\_\_\_\_

Contractor Phone #: \_\_\_\_\_ Contractor Email: \_\_\_\_\_

Project Description: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

Estimated cost: \$ \_\_\_\_\_ Date work will begin: \_\_\_\_\_

FEE: There is no fee for Curb & Sidewalk PA Home Improvement Contractor Registration No.: \_\_\_\_\_

#### OTHER INFORMATION

**Inspections are required PRIOR to pouring concrete.** Please contact the Borough's Building Inspector, Yerkes Associates, to schedule inspections:

**Frank Newhams (610) 656-2707 -or- Joe Lavelle (484) 318-8899**

Please refer to Page 2 for Curb and Sidewalk Specifications & Details.

**Borough of Narberth - 100 Conway Avenue, Narberth PA 19072**

**DO NOT POUR UNTIL THE EXCAVATION HAS BEEN INSPECTED  
BY THE BUILDING INSPECTOR**

**CURB SPECIFICATIONS**

- PennDOT Class A concrete - minimum 3,500 PSI
- Expansion joint required between curb and sidewalk
- NO MONOLITHIC POUR OF CURB AND SIDEWALK ALLOWED, with the exception of driveway apron, curb and sidewalk, which is allowed.
- Expansion joint between old and new curb if curb is longer than 20 feet, then one expansion joint is required in the center and expansion joints every 10 feet.
- Depth of concrete apron should be 6 inches
- Depth of curb is to be 18 inches
- 6" reveal required from street surface to top of curb, or shall match existing adjacent curb
- All curbs installed at an intersection must be ADA compliant

**SIDEWALK SPECIFICATIONS**

- PennDOT Class A concrete - minimum 3,500 PSI
- 1/4" slope per foot, toward street
- 4" depth of poured concrete, 6" depth where sidewalk abuts a driveway
- Expansion joint required every 15 feet, crack control joint every 5 feet
- Expansion joint required between curb and sidewalk
- All sidewalks installed at an intersection must be ADA compliant

**CURB & SIDEWALK DETAIL**

